



GENERAL NOTES:

- A. FOR VOICE/DATA OUTLETS PROVIDE A SINGLE GANG MUD-RUN WITH A 1" CONDUIT FROM THE TOP OF THE MUD-RUN TO ACCESSIBLE CEILING SPACE. TERMINATE CONDUIT WITH END CONNECTORS AT THREE INCHES FROM ADJACENT PULL STRING FOR GABLE PROTECTION. OUTLET SHALL BE AT THE SAME HEIGHT AS ADJACENT POWER OUTLET AND LESS THAN 18" SEPARATION. COORDINATE WITH ELECTRICAL.
- B. COORDINATE ALL DEVICE LOCATIONS WITH LATEST ARCHITECTURAL INTERIOR ELEVATIONS TO VERIFY DEVICES WILL NOT BE OBSTRUCTED.
- C. PROVIDE PULL STRING IN ALL CONDUITS FOR LATER USE.
- D. ALL PENETRATIONS THROUGH FIREWALLS WILL NEED FIRESTOP OF THE APPROPRIATE RATING.

NOTES:

1. PROVIDE CONDUIT AND BACKBOX FOR LOW VOLTAGE CABLING TO DENTAL EQUIPMENT MOUNTED TO CEILING.